



Arte nv
Industriezone "De Waerde"
Senator A. Jeurissenlaan 1210
B-3520 Zonhoven

Your message - reference

-

our reference

PW/720

Gent

2019-04-03

Certification report 19/720

1. Description of the wall covering:

Product family	Type 03: Vinyl wallcovering with water based ink
Total mass	Ca 170 - 605 g/m ²

2. Tests executed:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.



addressee

Arte nv

our reference

PW/720

Gent

2019-04-03

page

2

B – s2, d0

field of application: glued (starch glue applied at the rate of 200 gr/m²) on end-use substrates having a density of 1350 kg/m³ or higher and classified A2-s1,d0 or A1.

Related commercial names to this product group

Atelier
Artic Fever
Avalon
Curiosa
Figura
Focus
Galena
Lino
Mahlia
Mirage
Monsoon
New Heritage
Signature

The obtained classification is based on the next test reports

Aitex: 2018AN2975 dated 22-10-2018
Aitex: 2015AN0176 dated 29-01-2015
Aitex: 2019AN0293 dated 07-03-2019

Validity of the certificate

2020-01-28

Petra Wittevrongel

Product Certifier

